

CERTIFICATE

Ship: _____ LEONORE AF GRYT Call Sign: SFC3155

Home Port: _____ GRYT

AEROSOL EXTINGUISHING SYSTEM

We hereby certify that the FIRE-PRO AEROSOL EXTINGUISHING SYSTEM for ENGINE this day have been checked on board the LEONORE AF GRYT in Fyrudden.

The Plant have been left in Good and Working Condition.

1 pc Container FP 2000.

Installation date of containers: 2017.

Electric release system.

Release panel: FPX 103 C.

Fire detection central: 2 pcs Smokedetectors, 1 pc Heatdetector.

Type of certificate: Total System Control (see reverse side)

Next service 2026-12

Stockholm 2025-12-10

Presto AB

Hans Larsson

Hans Larsson



Presto AB
Gävlegatan 22
113 30 Stockholm

Växel
+46 10-452 00 00

E-mail
marineservice@presto.se

Hemsida
www.presto.se

Org.nr
556112-0584

Type of certificate

Total System Control, includes checking of (when applicable):

- Content of container.
- Release wires.
- Electronic release system.
- Warning alarms
- Fanstops
- Initiators
- Connections
- Release function test
- Control units
- Mechanical fitting
- Signs
- Rust damages etc.



Presto AB
Gävlegatan 22
113 30 Stockholm

Växel
+46 10-452 00 00

E-mail
marineservice@presto.se

Hemsida
www.presto.se

Org.nr
556112-0584