



TURVANASI

RAUMAN SAMMUTIN OY

www.raumansammutin.fi

CERTIFICATE

This is to certify that on board T/B AMIRAALI, IMO 6801066, in the port of RAUMA, Finland, the **Stationary FS-49 Gas (Halotron) Extinguishing system**, as stated below, has been inspected and serviced, if necessary, on the day of 2.6.2020.

EQUIPMENT

TYPE	AMOUNT	SIZE	SPECIFICATIONS
Stationary FS-49 syst. 67,5 ltr/52 bar	2	67,5 ltr	Halotron

Manuf. 1999-2000/ serv. 2016

The above mentioned equipment has been left in good working order with date markings.

Inspection and service of fire fighting equipment:

Rauman Sammutin Oy
Kairakatu 8, 26100 RAUMA, FINLAND
Tel.int. +358 44 550 1223

Rauman Sammutin Oy
Papinhaarkatu 16
26100 Rauma
Pub. 02-8220 230, Fax 02-8239 930

Inspector: _____

Jani Koivunen

Inspector approved by Kiwa Inspecta



**TURVANASI****RAUMAN SAMMUTIN OY**

www.raumansammutin.fi



Name of ship	Flag	Port of registry	IMO
"T/B AMIRAALI"	Finland	Rauma	6801066

SERVICE CHART

Description of system: FS-49/Halotron high pressure system
 Type/Make: Swe-Fire/Bejaro, consisting of two cylinders
 Each of capacity 67,5 kg/max. 52 bar
 Remote release via cables, operating cabinet at the main deck
 Covering: Engine room, one line
 Pressure test date of cylinders (both) 2016

Description of inspection	Checked	Not checked	Serviced
1. Cylinder temperature: 16 deg. Celsius, Method: Liquid level	X		
2. Release valve and distribution valves secured	X		
3. Contents in cylinders checked	X		
4. All cylinder valves visually inspected	X		
5. All cylinder frames and connections checked for tightness	X		
6. Manifold- and distribution valves leak tested		X	
7. Main valve and distribution valve(s) tested	X		
8. Alarm and ventilation fan(s) (Manual)	X		
9. Discharge lines and nozzles inspected/blown through		X	
11. Installation reconnected and left in operational order	X		
12. Installation sealed and inspection date labels attached	X		
13. Cylinder pressure visually inspected (42 bar/43 bar)	X		

Performed/Recommended/Additional information
 Cylinders made 1999/2000; pressure tested 2016
 Recommendation: Release cabinet should be more visible at the deck


 Jani Koivunen
 Inspector

Rauman Sammutin O Rauma
 2.6.2020 Date
 Papinhaa 16 Place
 26100 Rauma
 Puh. 02-8220 230. Fax 02-8239 930