

Inspection of Fire Extinguishing System

| Year: 2024 | Month: 05 | Day: 06 | Name of vessel: Lots 031 Golje | | Imo: | |
|--|-----------------------|---|-------------------------------------|--|-------------------------------------|--------------------------|
| Call sign: SKGM | | | Home port: Norrköping | | Place of service: Iggesund | |
| E-mail/Phone nr: anna-karin.norling-jonsson@sjofartsverket.se | | | | Classification: RINA | | |
| Type of cylinders: Co2 | No of cylinders: 3 | Contents of cylinders: 26 Kg | Volume of each: 40 Lit | Pressure test date of cylinders: 2023 | | |
| Type of pilot cylinders: | No of cylinders: | Contents of pilot cylinders: | Volume of each: | Pressure test date of cylinders: | | |
| Manufacturer of plant: Tempus Pnem | | Total system control: <input checked="" type="checkbox"/> | | Level check: <input type="checkbox"/> | | |
| Covering: Maskinrum | | | | | | |
| Description of inspection test | | | Test carried out | Test not carried out | N/A | REMARK |
| 1. Disconnect all main valves and all release contrivance | | | <input checked="" type="checkbox"/> | - | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. Content in cylinders/Tank | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. Cylinders racking and connections | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4. Content in pilot cylinders | | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 5. Gauges | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6. Pressure switches | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7. Manifold | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 8. Main valve and distribution valve | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 9. Manually operated release system: <input checked="" type="checkbox"/> | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 10. Wire operated release system: <input type="checkbox"/> | | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 11. Pneumatic operated release system: <input type="checkbox"/> | | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 12. Electric release system: <input type="checkbox"/> | | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 13. Time relay: <input type="checkbox"/> | | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 14. Time delay: <input type="checkbox"/> No of seconds: | | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 15. Distribution lines and nozzles | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 16. Alarm | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 17. Type of fan stop | | Automatic: <input checked="" type="checkbox"/> | Manually: <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 18. Leakage test | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 19. Compressor | | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 20. All instruction name plates and charts on installation | | | <input checked="" type="checkbox"/> | - | <input type="checkbox"/> | <input type="checkbox"/> |
| 21. Warning signs | | | <input checked="" type="checkbox"/> | - | <input type="checkbox"/> | <input type="checkbox"/> |
| 22. Co2 warning device | | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 23. Fire detection central: Dafo | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 24. No of Sd: 2 | | No of Hd: | No of MCp: | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 25. Reset the system to working condition | | | <input checked="" type="checkbox"/> | - | - | <input type="checkbox"/> |

For approved certificate no remarks according to No: 2.3.4.7.8.9.10.11.12.13.14.16. and 19. for Lowpressure system

